
OWEC Workshop

Assessing Wildfire Risk: Pacific Power

Historic Fire Weather Days reconciled using NARR data at 32 km cell resolution


- Landfire data with Anderson Fuel Models (30 km cells)
- Local Terrain Data
- Monte Carlo ignition simulation
- Increased simulation based on structure density (acting as proxy for population)
- 6 hour periods using ELMFIRE (Eulerian Level set Model for Fire Spread) fire simulation software
- Perimeters consolidated within grids
- Each grid scored based on perimeter persistence
- Calibrated to California severity using iUTI (integrated threat value)

Extending California Modeling Process Across PacifiCorp




- Used Jenks natural breaks to segment severity within each grid
- Calibrated to California severity using iUTI (integrated threat value)
- Resulted in long-term fire threat area, designated as Fire High Consequence Area (FHCA)


Extending California Modeling Process Across PacifiCorp




Pacific Power Oregon FHCA



Northern Oregon



Southern Oregon




5


Pacific Power Oregon PSPS Areas

State	PDZ Name	Op Area	Substations	Circuit List	Customers	Dist. OH miles	Dist. UG miles
OR	Hood River Rural	Hood River	Kenwood Hood River	5K50, 5K70	1,846	108.6	34
OR	Hood River Urban	Hood River	• Hood River	5K37, 5K43, 5K44, 5K74	6,498	72.5	51.5
OR	Cave Junction	Grants Pass	Selma New Obrien Cave Junction	5R52, 5R53, 5R65, 5R106	5,473	326.8	92.2
OR	Fielder Creek	Grants Pass	Fielder Creek	4R33, 4R34	2,686	131.2	55.4
OR	Glendale	Grants Pass	Glendale	5R133, 5R143	2,503	192.1	43.5
OR	Jerome Prairie	Grants Pass	Jerome Prairie	5R62, 5R63	3,198	153.9	67.7
OR	Merlin	Grants Pass	• Easy Valley • Merlin	5R232, 5R234, 5R248, 5R259	6,388	265.9	179.1
OR	South Rogue River	Grants Pass	Rogue River Agness Ave Park Street Applegate	5R77, 5R78, 5R114, 5R172, 5R267	6,974	191.9	98.7
OR	Cascade-Siskiyou National Monument	Medford	Oak Knoll	5R55	1,484	140.1	57.4
OR	Lost Creek Lake	Medford	Prospect Central Red Blanket	5R40, 7R5	725	44.4	30.4
OR	Shady Cove	Medford	Takelma Dodge Bridge	4R9, 4R35	3,997	216.9	68.5
OR	Riddle Myrtle Creek	Roseburg	Riddle Veneer Riddle Myrtle Creek	5U1, 5U2, 5U3, 5U23, 5U50,	6,630	258.1	50.1

PacifiCorp's Wildfire Risk Rubric




PacifiCorp's Wildfire Risk Rubric, throughout the life of the WMP



Public Safety Power Shut-off Criteria

8



Additional Criteria

- Environmental
- Locational
- Situational

Public Safety Power Shut-off

Pacific Power Emergency Operation Center (EOC) Active

While mainly elevated through environmental conditions (Precipitation and wind); the decision to implement PSPS considers additional criteria:

Environmental

- ✓ Recent precipitation
- ✓ Wind directionality
- ✓ Recent fire activity throughout service territory


Locational

- ✓ Alternative ways to re-route power to affected areas
- ✓ Impacts on mandatory or voluntary evacuation orders in place (ingress / egress routes)

Situational

- ✓ Real-time situational awareness information from personnel positioned in the impacted areas identified as potentially at risk
- \checkmark Current fire activity throughout service territory
- ✓ Input from local emergency services and response authorities

Daily (and week ahead) Assessment of Fire Risk



9