

OPERATION & MAINTENANCE MANUAL

Water Quality Biofiltration Swale

Manual prepared: July 2019

DFI No. D00615



Figure 1: DFI No. D00615, looking [west]

Identification

Drainage Facility ID (DFI): D00615
Facility Type: Water Quality Biofiltration Swale
Construction Drawings: (V-File Numbers) 45v-073

Location: District: 3
Highway No.: 162
Mile Post: 3.83 to 3.83, [left]

1. Manual Purpose

The purpose of this manual is to outline inspection needs and summarize maintenance actions.

2. Facility Location

The location map below details the facility location. The highway, mile posts, side streets, access location, and stormwater flow directions are noted on the map.

Facility location type: Roadway shoulder

Flow direction: [south to north]




Figure 2: Facility location map

3. Facility Summary

The length and width of a swale is based on the bottom dimensions.

The bottom length and bottom width of the swale is:


| Bottom Length (feet) | Bottom Width (feet) |
|----------------------|---------------------|
| 105 | 9 |



The depth of the swale is the vertical distance measured from the bottom of the swale to the top. The slope of the swale sides is presented by a vertical distance (rise) followed by the horizontal distance (run).

Depth and side slopes:

| Depth (feet) | Rise (feet) | Run (feet) |
|--------------|-------------|------------|
| 1.5 | 1 | 6 |



Site Specific Information: Stormwater runoff from highway 162 enters inlets along the concrete barrier before entering a pipe underneath highway 162 and flows to the north to the swale. Water exits in a ditch parallel to Gaffin road.

4. Facility Access

Maintenance access to the facility:

| | |
|--|---|
| <input type="checkbox"/> Roadside pad | <input checked="" type="checkbox"/> Roadside shoulder |
| <input type="checkbox"/> Access road with Gate | <input type="checkbox"/> Access road without Gate |



Figure 3: [access from shoulder looking west]

5. Operational Components / Maintenance Items

Classification

This facility is classified as an:

| | |
|---|---|
| <input checked="" type="checkbox"/> On-line Swale | <input type="checkbox"/> Off-line Swale |
| A swale that does not include a high flow bypass component; flow drains into and through the facility | A swale that treats low/small flows and diverts high flows using a bypass component |

Bypass Component

This facility includes a high flow bypass component:

| | |
|---|--|
| <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes |
| There is no bypass component. High flows drain into and through the facility | There is a bypass component. Only low/small flows drain into the swale. High flows are diverted around the swale using a bypass component |

Operational Components

A swale has many components that assist with treatment, conveyance, and reducing flow velocity to minimize erosion. The components in use can vary depending if the facility was designed to operate on-line or off-line. The facility components table (**Table 1**) has been provided to highlight the applicable components for this facility. The component is in use when the box contains an “x” (e.g.).

The Standard Operation Manual for Water Quality Biofiltration Swales (implemented March 2017) outlines facility operation, typical footprint configuration, and component definitions and details. A link to the manual is attached to the feature marker in TransGIS.

<https://gis.odot.state.or.us/TransGIS/>

Operational Plan

The applicable standard operational plan for this facility is:

| | | |
|---|---|--|
| <input checked="" type="checkbox"/> Operational Plan A | <input type="checkbox"/> Operational Plan B | <input type="checkbox"/> Operational Plan C |
| An on-line swale with roadside ditches | An on-line swale with piped inlets and outlets | An off-line swale with a piped high flow bypass |
| A standard operational plan illustrates the general facility footprint configuration and explains the purpose of each facility component. Operational plans (A, B, C) are provided in the Standard Operation Manual. | | |

See Appendix A for the site specific operational plan.

Maintenance Items

Operational components marked in **Table 1** should be inspected and maintained according to Section 7. Each facility component is defined and detailed in the Standard Operation Manual using the associated ID number indicated below.

| Table 1: Swale Components | | ID # |
|----------------------------------|--------------------------|-------------|
| Manholes/Structures | | |
| Pre-treatment manhole | <input type="checkbox"/> | S1 |

| | | |
|--|--|------------|
| Weir type flow splitter/flow splitter manhole | <input type="checkbox"/> | S2 |
| Orifice type flow splitter/flow splitter manhole | <input type="checkbox"/> | S3 |
| Standard manhole | <input type="checkbox"/> | S4 |
| Swale Inlet | | |
| Pavement sheet flow | <input checked="" type="checkbox"/> | S5 |
| Inlet Pipe (s) | <input checked="" type="checkbox"/> | S6 |
| Open channel inlet | <input type="checkbox"/> | S7 |
| Riprap pad | <input checked="" type="checkbox"/> | S8 |
| Ground Cover | | |
| Grass bottom | <input checked="" type="checkbox"/> | S9 |
| Grass side slopes | <input checked="" type="checkbox"/> | S10 |
| Granular drain rock | <input type="checkbox"/> | S11 |
| Plantings | <input type="checkbox"/> | S12 |
| Underground Components | | |
| Geotextile fabric | <input type="checkbox"/> | S13 |
| Water quality mix | <input checked="" type="checkbox"/> | S14 |
| Perforated pipe | <input type="checkbox"/> | S15 |
| Porous pavers (access grid) | <input type="checkbox"/> | S16 |
| Flow Spreader | | |
| Rock basin | <input checked="" type="checkbox"/> | S17 |
| Anchored board (midpoint of swale or every 50 feet along swale bottom) | <input type="checkbox"/> | S18 |
| Other: concrete flow spreader | <input checked="" type="checkbox"/> | S19 |
| Swale Outlet | | |
| Catch basin with grate | <input type="checkbox"/> | S20 |
| Outlet Pipe (s) | <input type="checkbox"/> | S21 |
| Open channel outlet | <input checked="" type="checkbox"/> | S22 |
| Auxiliary Outlet: | <input type="checkbox"/> | S23 |
| Outfall Type | | |
| Waterbody (Creek/Lake/Ocean) | <input type="checkbox"/> C <input type="checkbox"/> L <input type="checkbox"/> O | S24 |
| Ditch | <input checked="" type="checkbox"/> | S25 |
| Storm drain system | <input type="checkbox"/> | S26 |
| Outfall Components | | |
| Riprap pad | <input type="checkbox"/> | S27 |
| Riprap bank protection | <input type="checkbox"/> | S28 |

6. Maintenance

Maintenance Frequency/Maintain Records

- a. Inspect annually. Preferably prior to the rainy season.
- b. Clean and maintain as necessary. Refer to Activity 125 for conditions when maintenance is needed.
- c. Keep a record of inspections, maintenance, and repairs.

Maintenance Guide/Maintenance Actions

The ODOT Routine Road Maintenance Water Quality and Habitat Guide (the *Blue Book*) outlines the standard maintenance actions for water quality facilities under Activity 125.

There are standard maintenance tables for standard ODOT designs. The maintenance tables describe the maintenance component, the defect or problem, the condition when maintenance is needed, and the recommended maintenance to correct the problem. Use the following tables to maintain ODOT swales:

- Table 1 (General Maintenance): Contains general maintenance and inspection guidelines that are applicable to all ODOT water quality facilities
- Table 3 (Maintenance of Water Quality or Biofiltration Swales): Contains maintenance information for swales

The *Blue Book* can be viewed at the following website:

http://www.oregon.gov/ODOT/Maintenance/Documents/blue_book.pdf

7. Limitations

Access grid installed:

| | |
|---|------------------------------|
| <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes |
| There are no duty porous pavers installed in this swale | |

Swales are designed to allow equipment access along the bottom. If an access grid is **NOT** installed, vehicles entering the swale can create depressions (tire ruts), damage vegetation, and damage structural components (e.g. flow spreaders). These conditions may result in poor treatment and drainage performance.

Equipment wheels should be kept on the tops and side slopes. Mower arms may be run along the swale bottom.

8. Waste Material Handling

Material removed from the facility is defined as waste by the Department of Environmental Quality (DEQ). Refer to the roadwaste section of the ODOT Maintenance Yard Environmental Management System (EMS) Policy and Procedures Manual for disposal options:

http://www.oregon.gov/ODOT/Maintenance/Documents/ems_manual.pdf


Contact any of the following for more detailed information about management of waste materials found on site:

| | |
|-----------------------------------|----------------|
| ODOT Clean Water Unit | (503) 986-3008 |
| ODOT Statewide Hazmat Coordinator | (503) 667-7442 |
| ODOT Region 1 Hazmat Coordinator | (503) 731-8290 |
| ODOT Region 2 Hazmat Coordinator | (503) 986-2647 |
| ODOT Region 3 Hazmat Coordinator | (541) 957-3594 |
| ODOT Region 4 Hazmat Coordinator | (541) 388-6186 |
| ODOT Region 5 Hazmat Coordinator | (541) 963-1590 |
| ODEQ Northwest Region Office | (503) 229-5263 |


A Appendix A – Site Specific Operational Plan

Contents:

Operational Plan: DFI D00615



- LEGEND:**
- Photo Location / Direction
 - Facility Component (see table 1 in O&M Manual)
 - Manhole
 - Ditch Line
 - Swale Bottom
 - Storm Pipe
 - Conveyance Direction
 - Pavement / Facility Flow Path



FLOW SPREADER DETAIL
N.T.S.

SECTION A-A
N.T.S.

SECTION B-B
N.T.S.

PLAN
N.T.S.



DFI D00615
MAINTENANCE DISTRICT 3 OR22
WATER QUALITY BIOFILTRATION SWALE
NORTH SANTIAM HIGHWAY MP 3.83
MARION COUNTY

Prepared By: _____
Consultant

Drafted By: _____
Michael Skelton

B Appendix B – Project Contract Plans

Contents:

Site Specific Subset of Project Contract Plan 45v-073

STATE OF OREGON
DEPARTMENT OF TRANSPORTATION

PLANS FOR PROPOSED PROJECT

GRADING, DRAINAGE, STRUCTURES, PAVING, SIGNING,
ILLUMINATION, SIGNALS & ROADSIDE DEVELOPMENT

**OR 22 BRIDGE VERTICAL CLEARANCE
BRIDGE PROJECTS**

NORTH SANTIAM HIGHWAY
MARION COUNTY
JULY 2012

CORDON ROAD O'XING
BRIDGE NO. 08473 (M.P. 2.82)

END OF CONTRACT
NH-S162(050)
STA. "NS" 626+50 (M.P. 10.04)

ALBUS ROAD O'XING
BRIDGE NO. 08077 (M.P. 10.04)

| INDEX OF SHEETS | |
|-----------------|-----------------|
| SHEET NO. | DESCRIPTION |
| 1 | Title Sheet |
| 1A | Index Of Sheets |
| 1A-2 | Std. Drg. Nos. |


BEGINNING OF CONTRACT

NH-S162(050)
STA. "NS" 174+44 (M.P. 1.67)

**LANCASTER
DRIVE O'XING**
BRIDGE NO. 07770
(M.P. 1.91)

END OF PRESERVATION
STA. "NS" 358+76 (M.P. 5.16)

72ND AVENUE O'XING
BRIDGE NO. 08074 (M.P. 5.92)



Overall Length Of Project - 8.37 Miles

ATTENTION:
Oregon Law Requires You To Follow Rules Adopted By The Oregon Utility Notification Center. Those Rules Are Set Forth In OAR 952-001-0010 Through OAR 952-001-0090. You May Obtain Copies Of The Rules By Calling The Center. (Note: The Telephone Number For The Oregon Utility Center Is (503) 232-1987.)

PLANS PREPARED FOR
OREGON DEPARTMENT OF TRANSPORTATION
BY:



3470 Pipebend Place
Suite 170
Salem, OR 97301
t: 503.362.4675 f: 503.362.5078

OREGON TRANSPORTATION COMMISSION
Pat Egan CHAIR
Mary F. Olson COMMISSIONER
David Lohman COMMISSIONER
Mark Frohnmayer COMMISSIONER
Tommy Boney COMMISSIONER
Matthew L. Garrett DIRECTOR OF TRANSPORTATION

These plans were developed using ODOT design standards. Exceptions to these standards, if any, have been submitted and approved by the ODOT Chief Engineer or their delegated authority.

Approving Authority: *Ed Chamberland* 5/14/12
Signature & date

Ed Chamberland, Sr. P.M.
Print name and title


[Signature]
Concurrence by ODOT Chief Engineer

**OR22 BRIDGE VERTICAL CLEARANCE
BRIDGE PROJECTS**

| | | |
|--|----------------|-----------|
| NORTH SANTIAM HIGHWAY MARION COUNTY | | |
| FEDERAL HIGHWAY ADMINISTRATION | PROJECT NUMBER | SHEET NO. |
| OREGON DIVISION | NH-S162(050) | 1 |

T. 7 S., R. 2 W., W.M.
T. 8 S., R. 2 W., W.M.
T. 8 S., R. 1 W., W.M.






- ① See Sht. 12, Note 7
Inst. 12" storm sew. pipe
5' depth
- ② Sta. "NS" 277+90, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
Inst. 12" storm sew. pipe - 250'
5' depth
- ③ Sta. "NS" 280+40, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
Inst. 12" storm sew. pipe - 230'
5' depth
- ④ Sta. "NS" 282+70, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
Inst. 12" storm sew. pipe - 200'
5' depth
- ⑤ Sta. "NS" 284+70, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
Inst. 12" storm sew. pipe - 190'
5' depth
- ⑥ Sta. "NS" 286+60, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
- ⑦ Sta. "NS" 288+20, 1.1' Lt.
Const. Type G-2 inlet with 18" sump
Inst. 12" storm sew. pipe - 130'
5' depth
- ⑧ Sta. "NS" 288+20, 1.1' Lt.
Inst. 18" storm sew. pipe - 80'
5' depth, S.I. = 0.5%
I.E. (Outfall) = 250.50
Const. sloped end, Lt.
Inst. culvert field marker
(For details, see sht. GJ)
- ⑨ Const. water quality swale, D00615 - 105'
9' flat bottom, 1:6 max. side slopes
Inst. stormwater field marker
(For details, see sht. GJ & GJ-9)
- ⑩ Seed and mulch water quality swale with water
quality seeding, mix no. 1 - 0.07 ac.
- ⑪ Trench resurf. - 380 sq. yd.
(For detail, see sht. 2B-2)
- ⑫ Retain and protect extg. pole

Wetland Shown Thus:

Note:
1. Station/callouts for Type "G-2" inlets are
to face of barrier.




| | |
|--|---------------------------|
| OREGON DEPARTMENT OF TRANSPORTATION | |
| WHPacific | |
| 3470 Pipebend Place NE Ste 170 Salem, OR 97301 t: 503.362.4675 f: 503.362.5078 | |
| OR22 BRIDGE VERTICAL CLEARANCE BRIDGE PROJECTS | |
| NORTH SANTIAM HIGHWAY MARION COUNTY | |
| Design Team Leaders - Sarah Heller, Ed Chamberland Designed By - Calvin Larwood, Travis Sater Drafted By - Linda Foote | |
| GENERAL CONSTRUCTION | SHEET NO. 13 |

STORMWATER CONTROL FIELD FACILITY MARKER TABLE

| FACILITY LOCATION | | DFI # | TYPE S2 MARKER LOCATION | | TYPE S1 MARKER | |
|-------------------|-------|---------|-------------------------|-----|----------------|-------|
| STATION | MP | | BEGIN | END | RED | GREEN |
| "NS" 170+65, Rt. | 1.60 | D 00611 | ✓ | | | |
| "NS" 236+40, Rt. | 2.85 | D 00612 | ✓ | | ✓ | |
| "NS" 236+40, Lt. | 2.85 | D 00613 | | ✓ | | ✓ |
| "NS" 239+20, Rt. | 2.90 | D 00612 | ✓ | ✓ | | ✓ |
| "NS" 239+50, Lt. | 2.90 | D 00613 | ✓ | | ✓ | |
| "NS" 264+67, Lt. | 3.38 | D 00614 | | ✓ | | ✓ |
| "NS" 265+72, Lt. | 3.40 | D 00614 | ✓ | | ✓ | |
| "NS" 288+20, Lt. | 3.83 | D 00615 | ✓ | | | |
| "NS" 400+60, Rt. | 5.95 | D 00616 | ✓ | | | |
| "NS" 395+60, Lt. | 5.86 | D 00617 | ✓ | | | |
| "NS" 605+10, Rt. | 9.63 | D 00618 | ✓ | | ✓ | |
| "NS" 612+80, Rt. | 9.78 | D 00618 | | ✓ | | ✓ |
| "NS" 621+20, Rt. | 9.94 | D 00619 | ✓ | | ✓ | |
| "NS" 626+50, Rt. | 10.04 | D 00619 | | ✓ | | ✓ |

See drg. no. RD399

✓ Check where appropriate
 Red = Beginning of facility
 Green = End of facility




WATER QUALITY BIOFILTRATION SWALE
 N.T.S.

CULVERT DRAINAGE FACILITY MARKER TABLE


| FACILITY LOCATION | | TYPE 1 MARKER | |
|-------------------|------|---------------|----------------|
| STATION | MP | INLET | INLET & OUTLET |
| "NS" 183+80 | 1.85 | ✓ | |
| "B" 189+20 | 1.96 | ✓ | |
| "D" 192+20 | 2.01 | ✓ | |
| "NS" 237+60 | 2.87 | | ✓ |
| "NS" 266+50 | 3.40 | ✓ | |
| "NS" 288+20 | 3.82 | ✓ | |

See drg. no. RD398


✓ Check where appropriate



TYPICAL BRIDGE DRAIN CONNECTION
 N.T.S.



WATER QUALITY FILTER STRIP
 N.T.S.



OREGON DEPARTMENT OF TRANSPORTATION

WHPacific 3470 Pipebend Place NE Ste 170
 Salem, OR 97301
 t: 503.362.4675 f: 503.362.5078


**OR22 BRIDGE VERTICAL CLEARANCE
 BRIDGE PROJECTS**

**NORTH SANTIAM HIGHWAY
 MARION COUNTY**



Design Team Leader - Ed Chamberland
 Designed By - Travis Sater
 Drafted By - Linda Foote

STORMWATER DETAILS

SHEET NO. **GJ**




• 3' at 1:6 side slope




Note: Place 0-15 lb rock gradation as the top layer of the flow spreader.

SECTION C-C
N.T.S.



ROCK BASIN FLOW SPREADER



CONCRETE BASIN FLOW SPREADER


OREGON DEPARTMENT OF TRANSPORTATION

WHPacific 3470 Pipebend Place NE Ste 170
Salem, OR 97301
t: 503.362.4675 f: 503.362.5078

**OR22 BRIDGE VERTICAL CLEARANCE
BRIDGE PROJECTS**

**NORTH SANTIAM HIGHWAY
MARION COUNTY**

Design Team Leader - Ed Chamberland
Designed By - Travis Sater
Drafted By - Linda Foote




RENEWS: 12-31-2013

STORMWATER DETAILS


SHEET NO.

GJ-2




WATER QUALITY BIOFILTRATION SWALE (WQBS)
SCALE: 1"=40'


LEGEND
Up Down
Slope direction indicator



SECTION A-A
SCALE: 1"=40'



WQBS PROFILE
SCALE: 1"=40'



RENEWS: 12-31-2013

| | |
|--|----------------------------------|
| <p>OREGON DEPARTMENT OF TRANSPORTATION</p> | |
| <p>WHPacific 3470 Pipebend Place NE Ste 170 Salem, OR 97301 t: 503.362.4675 f: 503.362.5078</p> | |
| <p>OR22 BRIDGE VERTICAL CLEARANCE BRIDGE PROJECTS</p> <p>NORTH SANTIAM HIGHWAY MARION COUNTY</p> | |
| <p>Design Team Leader - Ed Chamberland Designed By - Travis Sater Drafted By - Linda Foote</p> | |
| <p>STORMWATER DETAILS</p> | <p>SHEET NO. GJ-9</p> |