



**SYSTEM INSPECTION CHECKLIST REPORT – Fuji Clean CE & CEN Systems**

To be completed by authorized service provider at each inspection/service visit - once every 6 months. Please follow the O&M Maintenance Program in the Fuji Clean O&M Manual. Contact Fuji Clean USA with questions, comments and/or troubleshooting assistance. Authorized Service Provider must maintain a copy of this report in records.

SYSTEM SITE	AUTHORIZED SERVICE PROVIDER
Name: _____	<b>SERVICE DATE:</b> _____
Address: _____ _____	Name: _____
Town/State: _____	Company: _____
Contact: _____	Town/State: _____
Contact Info: _____	License No. (if applicable): _____
	Contact Info: _____

<u>SERVICE PROCEDURE / OPERATION</u>	<u>COMMENT / DATA / OBSERVATION (use reverse if nec.)</u>
<input type="checkbox"/> 1. Outside Environment Check	_____
<input type="checkbox"/> 2. Blower Box Check	_____
<input type="checkbox"/> 3. Blower Operation and Blower Alarm Check	_____
<input type="checkbox"/> 4. Replace blower Consumable Components if nec.	_____
<input type="checkbox"/> 5. Treated Effluent Check	_____
Clarity (Required)	_____
Odor (Required)	_____
pH (Required)	_____
DO (Recommended)	_____
<input type="checkbox"/> 6. High Water Float Switch Check	_____
<input type="checkbox"/> 7. Inflow Pipe Check	_____
<input type="checkbox"/> 8. Transfer Scum to Sedimentation Chamber	_____
<input type="checkbox"/> 9. Check/Set Recirculation Control Valve	_____
<input type="checkbox"/> 10. Check/Set Aeration Balance Control Valve	_____
<input type="checkbox"/> 11. Check/Set Effluent Airlift Valve	_____
<input type="checkbox"/> 12. Backwash and Sludge Transfer (Important!)	_____
<input type="checkbox"/> 13. Check/Clean Effluent Airlift Pipe	_____
<input type="checkbox"/> 14. Check/Clean Recirculation Airlift Pipe	_____
<input type="checkbox"/> 15. Refill Chlorinator (if applicable)	_____
<input type="checkbox"/> 16. Clean Aeration Pipes (if necessary)	_____
<input type="checkbox"/> 17. Measure Sludge and Pump out if necessary*	_____
Sedimentation Chamber (Chamber 1)	_____
Anaerobic Chamber (Chamber 2)	_____
<input type="checkbox"/> 18. Check Flow Monitor Component (if Applicable)	_____

\* Pump out reminder. If 24" or more of sludge accumulates in the Sedimentation Chamber (1<sup>st</sup> chamber) or 18" or more in the Anaerobic Chamber (2<sup>nd</sup> chamber), the system should be pumped. Pump Anaerobic Chamber (2<sup>nd</sup> chamber) first, followed by the Sedimentation Chamber (1<sup>st</sup> chamber). Please refer to Fuji Clean USA O&M Manual.