





GENERAL NOTES FOR ALL DETAILS ON THIS SHEET:

- 1. All concrete shall be commercial grade concrete.
- 2. End all reinforcing 3" clear of ground, forms or top surface, unless otherwise shown.
- 3. Trowel finish top surface of saddle, and cradle.
- 4. Reinforcement shall be # 4 vertical & horizontal bars as shown.
- 5. See Std. Dwg. RD300 for trench backfill, bedding, etc.
- 6. See Std. Dwg. RD336 for tracer wire details (When required).
- 7. Pipe over 72" diameter are structures, and are not applicable to this drawing.

SDR DATE

All material and workmanship shall be in accordance with the current Oregon Standard Specifications The selection and use of this Standard Drawing, while designed in accordance with generally accepted engineering principles and practices, is the sole responsibility of the user and should not be used without consulting a Registered Professional Engineer.

OREGON STANDARD DRAWINGS

14-JUL-2014

CONCRETE ENCASEMENT, CRADLE, AND CAP DETAILS

2021