

Rule to be Amended	Intent/Reason	Page Number(s) in Notice of Proposed Rulemaking
OAR 333-061-0010(3)	Clarify the scope and intent of the rules to specify facilities using treatment for legionella (or other “treatment techniques”) will be considered public water systems.	3-4
OAR 333-061-0020(83)	Correct the definition for maximum contaminant level (MCL) by removing incorrect turbidity reference.	9
OAR 333-061-0020(31), OAR 333-061-0025, OAR 333-061-0030 & OAR 333-061-0090	Ensure OHA has clear authority to enforce MCL violations.	6, 13-16 & 147
OAR 333-061-0036(5)(e)	Delete Table 33 because it is no longer relevant.	42-43
Multiple – OAR 333-061-0036 through OAR 333-061-0265	Ensure consistency in table formatting and improve readability.	56, 58-59, 77-78, 87-88, 140, 158-159, 161-163 & 168
OAR 333-061-0036(6)(b)–(e)	Clarify “routine” samples are necessary to meet regular coliform monitoring requirements.	48-49 & Table 34 (now 33) on page 76

OAR 333-061-0036(6)(k)	Clarify source assessment monitoring is required when disinfection doesn't achieve 4-log inactivation.	50
OAR 333-061-0036(10)(h)	Repeal lead service line replacement plan text, which may be implemented by DWS in the future.	61-62
OAR 333-061-0036(11)	Added table for calculating disinfection with chlorine in groundwater.	63 & 77-78 (Table 37)
OAR 333-061-0042(?) & OAR 333-061-0097	Consolidate health effects language by repealing OAR 333-061-0097.	97, 99-100 & 149-154
OAR 333-061-0060(1)(a)	Repeal unnecessary requirement that plans be drawn to scale, which is not implemented.	131
OAR 333-061-0065(3)	Require water systems to have a contact person.	135
OAR 333-061-0070(11)(d)	Allow OHA to waive the annual cross connection fee.	137
OAR 333-061-0100(1) & (2)	Clarify monitoring reductions will be revoked if monitoring isn't conducted.	155-156
OAR 333-061-0540	Specify correct concentrations of total microcystins and cylindrospermopsin necessary to cease entry point monitoring, left out of 2022 rulemaking by accident.	169

800 NE Oregon St. Suite 640, Portland, OR 97232

Voice: 971-673-0405 | Fax: 971-673-0694

All relay calls accepted | oregon.gov/OHA